



GOVERNMENT OF KARNATAKA



DISTRICT PUBLIC HEALTH LABORATORY
DISTRICT SURVEILANCE UNIT, DISTRICT HOSPITAL CAMPUS, ATHANI ROAD, VIJAYAPUR

E-mail: dsubijapur@yahoo.co.in, dphlvjp@gmail.com

Phone.No: 08352-270320

DEPARTMENT OF MICROBIOLOGY

WATER QUALITY ANALYSIS (BACTERIOLOGICAL) REPORT BY H₂S METHOD

| SL NO | SOURCE | DATE OF COLLECTION | LOCATION | VILLAGE / TALUKA | RESULT |
|----------|--------|--------------------|------------------------------------|------------------------|---|
| 84 | BORE | 20.05.2022 | DELHI PUBLIC SCHOOL, VIJAYAPUR, | ATALATTI, VIJAYAPUR | WATER IS FIT FOR HUMAN CONSUMPTION BACTERIOLOGICALY |

REPORT BY MPN METHOD

| | INTERPRETATION | | |
|-----------------|-----------------|----------|---------|
| TOTAL COLIFORMS | FECAL COLIFORMS | E.COLI | CLASS |
| 00 | NEGATIVE | NEGATIVE | CLASS-I |

INTERPRETATION

MPN COLIFORM COUNT TEST CLASSIFICATION

| | | · | | |
|-------------------------|--------------|-------------------------------|--|--|
| CLASS GRADING | | COLIFORM COUNT / 100ML (MPN) | | |
| Class -1 | Excellent | 0 | | |
| Class -2 | Satisfactory | 1-3 | | |
| Class -3 Suspicious | | 4-10 | | |
| Class -4 Unsatisfactory | | > 10 | | |

REMARKS-

- 1. Samples fit for consumption [POTABLE]
- 2. Please find the fecal contamination of water for both at source & supply
- 3. Chlorination of water should be done regularly,
- 4. If unfit, recollect the water samples & send for MPN test.
- 5. If unfit, identify the source of contamination.

MICROBIOLOGIST

DPHL DISTRICT HOSPITAL, VIJAYAPUR

PRINCIPAL,
DELHI PUBLIC SCHOOL
VIJAYAPURA.

CHAIRMAN, DELHI PUBLIC SCHOOL VIJAYAPURA.



TALUKA HEALTH OFFICE VIJAYAPUR

E-mail: thovijayapur@gmail.com

No/THO/VJP/10/2022-23

Date: 16-05-2022

To, The Principal Delhi Public School Attalatti Vijayapur.

Respected Sir,

With reference to the above cited subject, **Delhi Public School Attalatti** Vijayapur Karnataka State is situated in S.R. No.1074, requested to issue certificate regarding fit for health for residential purpose.

For that reason on 10-03-2022, I visited S.R. No.1074, Attalatti Vijayapur along with our office senior Health Inspecting Officer and examined the are and it is suitable for Health and Living environment Accordingly NOC is issued to Delhi Public School Attalatti Vijayapur Karnataka State.

Yours faithfully,

Taluka Health Officer Vijayapur

PRINCIPAL,
DELHI PUBLIC SCHOOL
VIJAYAPURA.

CHAIRMAN,
DELHI PUBLIC SCHOOL
VIJAYAPURA.