



C.NO.435/FSCR/DFO/VIJAYAPUR/2026

Date-04/09/2026

To,

The Trustee
Daksha Education Trust®
Delhi Public School
New Vittal Mandir Cross Road, Vijayapur
Tq & Dist- Vijayapur.

Sir

Sub :Issue of “**Fire Safety Compliance Report**”to“Daksha Education Trust®”
“Delhi Public School ” Situated at Sy.No.1074/k, Shiradi Sai Nagar,
Atalatti Village, Toravi, Tq-Tikota, Dist- Vijayapur.

Ref :1. NO:GBC(2)2100/2025 Date:03/02/2026

2. Application Req Letter Date:03/09/2026

3. C NO.373/FSR/DFO/VIJAYAPUR/2026 Date:04/08/2026

><<<*@<<<<

With reference to the subject above cited, the premises of “Daksha Education Trust®” “Delhi Public School ” Situated at Sy.No.1074/k, Shiradi Sai Nagar, Atalatti Village, Toravi, Tq-Tikota, Dist- Vijayapur. was inspected by The District Fire Officer, Vijayapur on 04/09/2026 with respect to Fire prevention, Fire fighting and Evacuation measures complied in the above premises and the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

“GROUP-B Educational Buildings

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	The Trustee Daksha Education Trust® Delhi Public School New Vittal Mandir Cross Road, Vijayapur Tq & Dist- Vijayapur
02.	Name and Address of the premises.	:	Delhi Public School Situated at Sy.No.1074/k, Shiradi Sai Nagar, Atalatti Village, Toravi, Tq-Tikota, Dist- Vijayapur
	Name and address of the Building owner	:	The Trustee Daksha Education Trust® Delhi Public School New Vittal Mandir Cross Road, Vijayapur Tq & Dist- Vijayapur
04.	Number of buildings	:	01 Building.
05.	Number of floors	:	G+3 Floors
06.	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	Class Room-02, Trustee Cabin-01, Strong Room-01, Principal Room-01, Admin Room-01, Lobby, FEE

6/5/26
04/09/26

			Room-01, Board Room-01, Discussion Room-01, Sick/Infirmary Room-01, Auditorium-01, ELE Room-01, Pantry Room-01, Boys & Girls Toilet Section
	1 st Floor	:	Class Room-06 no's, Language Lab-01, Lobby, Music Dance Room-01, Math Lab-01. Boys & Girls Toilet Section
	2 nd Floor	:	Class Room-06 no's, Computer Lab-02, Library Room-02, Activity Room-01. Boys & Girls Toilet Section
	3 rd Floor	:	Class Room-02 no's. Library Room-01. Boys & Girls Toilet Section
07.	Height of the building	:	14.80 mtr
08.	Site area	:	18721.30 Sq.Mtr
09.	Built-up area of each floor:-		
	Ground Floor	:	1431.09 Sq.Mtr
	1 st Floor	:	1249.99 Sq.Mtr
	2 nd Floor	:	1266.19 Sq.Mtr
	3 rd Floor	:	622.09 Sq.Mtr
10.	Total built-up area	:	4569.36 Sq.Mtr
11.	Surrounding properties:-		
	East	:	Agriculture Land
	West	:	Open Plot
	North	:	09.00 Mtr Approach Road
	South	:	Agriculture Land
12.	Set-back area available around the building :-		
	East	:	04.00 mtr
	West	:	04.00 Mtr
	North	:	20.00 Mtr
	South	:	04.00 Mtr
13.	School Dis Code	:	29030510323

B. On inspection of this Institutional premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No	Details	Existing (03)			Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 09.00 mtr wide road on the Northern side.			Adequate
02.	No. of entrances	Provided 01 No of entrance 01 Exit Northern side.			Adequate
03.	Width of entry / exit	Width of entry & Exit 04.30 mtr each.			Adequate
04.	Diesel generators.	Diesel generator of 15KVA capacities has been provided to supply alternative power supply.			Complied.
05.	No. of staircases available	Nos. of staircases	03 no's	G-1 st & 2 nd - 3 rd	The staircase must be free
		Width of	01.50 m	01.50 01.80 m	

Signature
04/09/24


		staircases		m		from Obstruction all the time.
		Width of treads	00.30 m	00.30 m	0.30 m	
		Height of risers	00.15 m	00.15 m	0.15 m	
		Nos. of riser per flight	12 no's	12 no's	12 no's	
		Height of handrails	01.00 m	01.00 m	01.00 m	
06.	Lift	01 lift has been provided with 04 person 320 kgs capacity.				Complied
07.	Fire extinguisher	Provided 16 nos of ABC extinguishers & 02 nos of CO2 extinguishers have been provided.				Complied
08.	Hose reel hose system	07 nos of Hose reel hose near the staircase (One hose reel hose system for every 1000 sq.mtrs) G.I Pipe of minimum 63 mm has been provided. The hose reel hose of min 19 mm size adequate length to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size .				Complied
09.	Terrace Tank	05 no of 2000 ltrs Capacity & 01 tank of 1000 ltr capacity terrace tank has been provided.				Complied
10.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	The system has been connected to two booster pump of 450 LPM or of 5 HP capacity. Further the system should be connected to an alternative source of power supply.				Complied
11.	Escape routes	Escape route shall be marked with luminous light/paint at in the building directing towards exists and emergency exists .				Complied
	Fire order	Fire safety indicating the details of actions to be taken in case of emergency has been displayed near each staircase landings with the telephone numbers of Vijayapura Fire Station 08352-270160,270101,112 and 101 numbers & telephone numbers of nearest Ambulance Service.				Complied
13.	Transparent Fire Retardant coat to the electrical panel & Distribution box	Transparent Fire Retardant coat has been done to the electrical panel & Distribution box				Complied
14.	No Smoking board	COPTA Sec-4 direction of No Smoking area , smoking here is an offence board has been written in English & Kannada both languages & is displayed at inside the entry/exit of the each floor.				Complied
15.	Fire Siren	A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.				Complied
16.	Nominate	Shri. Arshad Inamdar has been nominated as The Fire Nodal				Complied

04/09/26

	One Fire Nodal Officer	Officer.	
17.	Fire fighting training	02 persons have undergone basic Fire fighting training from 25/07/2024 to 26/07/2024 in the premises of R.A.Mundkur Fire & Emergency Servicee Academy Benagaluru. 1.Shri.Sumitkumar S Patil 2.Shri. Arshad Inamdar	At least 40% of employees shall be trained in basic fire fighting course at our R.A.Mundkur Fire and Emergency Services Training Academy, Bannerghatta Road, Bangalore-29, or Regional training centre hubballi or District Fire Station Vijayapur.
18.	Fire Safety Measures A:- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises. B:- Accumulation of combustible waste in and around the premises should be avoided. C:- Exit ways shall be always kept clear without any obstruction. D:- Liquefied petroleum gas should not be stored in the building. E:- Entrances shall not be kept locked/ latched during working hours and shall be free from obstruction. F:- During the class hours the class room door shall not be locked from inside to out side. G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing of “**Fire Safety Compliance Report**” to “Daksha Education Trust®” “Delhi Public School ” Situated at Sy.No.1074/k, Shiradi Sai Nagar, Atalatti Village, Toravi, Tq-Tikota, Dist- Vijayapur. Subjected to Maintain of all fire fighting installations in working condition.

This “**Fire Safety Compliance Report**” is valid for only one year from the date of issue.

Yours Faithfully

DISTRICT FIRE OFFICER
VIJAYAPUR-586108