



Adarsh Scientific Research Center & Testing Lab Pvt. Ltd.

C/o D.D. Vispute College of Pharmacy, Gut No. 104, Devad - Vichumbe, New Panvel, Dist Raigad 410206,

Email : adarshscientificresearch@gmail.com / asrctl@gmail.com

9136133088, 9923435783 ☎ 022-27462886, Fax: 022-27462889,

Corporate Office: Adarsh, Plot No. 41, Near Railway Station, New Panvel, Dist. Raigad 410206,

Contact No. 022-27462888, www.asrctl.com



TC-10632

Test Report No.: ASL/2026/09/04/R-125

Date of Report: 10/09/2026

TEST REPORT

ULR NUMBER	:	--			
Name Of Customer	:	DAKSHA EDUCATION TRUST			
Address	:	SHRI SHIRADI SAI NAGAR ATALATTI 586125 DIST: VIJAYAPURA			
Name of sample	:	RAW WATER	*Brand Name	:	Not given
Sample Collected By	:	Ravindra walhekar (Lab Representative)	Sample Quantity	:	6 x 1Ltr Bottle
			*Other Information (if any)	:	Not Applicable
*Batch No./Lot No.	:	Not given	Mode of Packing	:	Packed In Box
*Date of Mfg	:	Not given	*Date of Expiry	:	Not given
Date of Receipt	:	01/09/2026	Test	:	COMPLETE ANALYSIS
Analysis Start Date	:	04/09/2026	Analysis Completion date	:	10/09/2026
Sample Ref. Number	:	ASL/2026/09/04/125	*CM/L No	:	Not given
			*FSSAI Lic No	:	Not given
Sample Container Intact & Labeled (Condition)	:	Yes	Sample Appearance	:	Clear Colourless Liquid

Results of Analysis

Sr. No	Parameter	Result	Unit	Specifications (IS10500:2012) Acceptable Limit	Method Used
B	Microbiological Parameters				
1	E. coli	Not Detected	/100ml	Shall Not be Detected/100ml	IS: 15185 : 2016
2	Coliform	Not Detected	/100ml	Shall Not be Detected/100ml	IS: 15185 : 2016

*Information Provided By the customer

Remark: The above sample is Complies/~~Does not comply~~ as per IS 10500:2012 Reaff.2023 (Drinking Water) with respect to above parameters.

Scrawade

Reviewed By
Ms. Sheetal Gawade
Microbiologist



Bawa

Authorized Signatory
Dr. Gurpreet Bawa
Dy. Technical Manager

Terms & Condition

- The results reported relate only to be sample tested. In case a sample is not drawn the results apply to the sample as received.
- The test in full or in part shall not be produced, used for any legal action, without prior written approval of ASRCTL.
- The ASRCTL is not responsible for the authenticity of photocopied test report.
- This report reflects our findings and place of testing.
- Any correction to this report invalidates this certificate

--- End of the Report---